



U.S. Patent No. 6,951,619.

Dimensions in inches  
 Permanent Pool Volume = 2500 US gallons  
 The Hydroguard must be cleaned after the construction period if  
 it is used as a sediment and erosion control measure  
 The Hydroguard should be inspected once per year for stabilized  
 sites  
 Inspection will determine the maintenance frequency (annual  
 maintenance or once every two years typical for stabilized sites)  
 Sites with unstable conditions (exposed soil or materials storage)  
 will require more frequent inspection and maintenance

Hydroworks, LLC  
 50 S. 21st St., Kenilworth, NJ 07033  
 Phone: 888-290-7900 Fax: 888-783-7271  
 Web: www.hydroworks.com

Hydroworks HG8 (96"Ø)

PROJECT:

LOCATION:

REVISION DATE: 02/10/2011

